

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



95478
office use only
Log No.....
Permit No.....
Basin 82

NOTICE OF INTENT NO 64846

1. OWNER **James Jurschak**
MAILING ADDRESS **5975 Sierra Vista Way**
Reno NV 89510

ADDRESS AT WELL LOCATION **5975 Sierra Vista Way**

2. Location **SW 1/4 NW 1/4 Sec 7 T18N R19E**
PERMIT NO. **PARCEL NO. 040-573-04**

Washoe County

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Clay & cobbles.		0	22	22
Gravels.		22	29	7
Brown clay.		29	51	22
Gravels.		51	66	15
Clay.		66	147	81
Clay & rock.		147	165	18
Fractured rock.		165	201	36
Multy colored rock.		201	233	32
Clay.		233	235	2

8. WELL CONSTRUCTION					
Depth Drilled		Depth Cased			
HOLE DIAMETER (BIT SIZE)					
	From	To		From	To
10 5/8	inches	0	feet	100	feet
8 3/4	inches	100	feet	235	feet
	inches		feet		feet
CASING SCHEDULE					
Size O.D.	Weight/Ft.	Wall Thickness	From	To	
(Inches)	(Pounds)	(Inches)	(Feet)	Feet	
6 5/8	12.94	188	+1 1/2	235	
Perforations:					
Type Perforation	Factory				
Size perforation	3/32 x 3"				
From	155	feet to	235	feet	
From		feet to		feet	
From		feet to		feet	
From		feet to		feet	
From		feet to		feet	
Surface Seal	<input checked="" type="checkbox"/> YES	No			Seal Type:
Depth of Seal	100	feet			Neat Cement
	<input checked="" type="checkbox"/> Pumped				<input checked="" type="checkbox"/> Cement Grout
	Poured				Concrete Grout
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No			
From	100	feet to	235	feet	
9. WATER LEVEL					
Static water level	110	feet below	land surface		
Artesian flow	0	GPM	0	P.S.I.	
Water Temperature	cold	Degrees F		Quality	

RECEIVED
 05 APR - 1 AM 10:57
 STATE ENGINEERS OFFICE

Date started **2/26-05**
Date completed **3/3/-05**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
4	15		
8	40		
12	65		
15	125		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed *Steve McKay*
By driller performing actual drilling on site or contractor
Date **3-8 -05**