WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96074
Permit No.
Basin 207

NOTICE OF INTENT NO. 43203

1. OWNER Joseph Brokaw
MAILING ADDRESS 4354 So. townline Rd. Houghton Lake MI 48629
ADDRESS AT WELL LOCATION 67 N preston Ave

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 12 N/S R. 61 E. white pine County
PERMIT NO. (Issued by Water Resources) Parcel No. 013-022-14 Subdivision Name Preston town ship

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil cobbles		0	5	
Clay gravel conglomerate		5	12	
clay		12	19	
gravel		19	20	
Sandy Clay		20	37	
clay		37	47	
Sandy clay		47	55	
clay gravel con.		55	72	
gravel	water	72	72.5	
clay gravel con.		72.5	80	
gravel	water	80	81	
clay gravel con.		81	90	
gravel	water	90	91	
clay		91	102	
gravel	water	102	103	
clay gravel con.		103	116	
gravel	water	116	117	
clay gravel con.		117	130	

RECEIVED NOV 22 AM 11:51 STATE ENGINEER'S OFFICE

Date started Oct 13 2004
Date completed Nov. Nov 17 2004

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	25'	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130. Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8	Inches	50	Feet	130	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	12
6 5/8		Sch 40 PVC	12	130

Perforations:
Type perforation milled
Size perforation .30 x 15" x 6 row
From feet to feet
From 70 feet to 90 feet
From 110 feet to 130 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 47226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed (By driller performing actual drilling on site or contractor)
Date Nov 18-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627