

Log No. 96315
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.388

NOTICE OF INTENT NO. 5345-9

1. OWNER PHIL Colatorti ADDRESS AT WELL LOCATION 1163 CORTEZ
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SE 1/4 Sec. 12 T. 12 N/S R. 20 E Douglas County
 PERMIT NO. 1220-12510-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	11	11
COBBLES		11	30	19
BROWN CLAY-GRAVEL		30	60	30
LOOSE FRAC. ROCK		60	120	60
BROWN CLAY-GRAVEL	X	120	128	8
FRACTURED ROCK		128	170	42
MEDIUM GRAVEL	X	170	185	15
LARGE GRAVEL	X	185	220	35

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 50 Feet
9 7/8 Inches 50 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation 104.5" x 4"
 From _____ feet to _____ feet
 From 190 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 54 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 220 feet

9. WATER LEVEL
 Static water level 102 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 13 FEB 05

Date started 10 FEB 2005
 Date completed 13 FEB 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>		<u>1.5</u>

RECEIVED
 05 MAR 23 AM 2 07
 STATE ENGINEERS OFFICE