

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 910389
 Permit No. _____
 Basin 107

NOTICE OF INTENT NO. 48680

1. OWNER Alex + Renae Hammond ADDRESS AT WELL LOCATION 8 Owens Place Wellington, NV
 MAILING ADDRESS 17 Grandview Wellington NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 30 T. 12 N/S R. 24 E Lyon County
 PERMIT NO. NO Issued by Water Resources | 009-042-01 Parcel No. | Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Brown Silt</u>		<u>0</u>	<u>80</u>	
<u>Sandy Grey Silt</u>		<u>80</u>	<u>120</u>	
<u>Sand + Small Gravel</u>	<u>Grey Clay - Silt</u>	<u>120</u>	<u>160</u>	
<u>Grey Clay Sand</u>		<u>160</u>	<u>280</u>	
<u>Brown Sand Small Gravel</u>		<u>280</u>	<u>295</u>	
<u>Grey Clay Sand</u>		<u>295</u>	<u>345</u>	
<u>Brown Sand + Gravel</u>		<u>345</u>	<u>355</u>	
<u>Grey Clay</u>		<u>355</u>	<u>360</u>	

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>188</u>	<u>+2</u>	<u>360</u>

Perforations:
 Type perforation mill slot
 Size perforation 3/32
 From 280 feet to 300 feet
 From 340 feet to 360 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 360 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality ltt

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA PUMP & DRILLING Contractor
 Address P.O. BOX 2227 Contractor
DAYTON, NV 89403
 Nevada contractor's license number 46357
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-1-04

Date started 4-21- 2004
 Date completed 4-30 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>30</u>	<u>340</u>	<u>4-5</u>