COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96396
Permit No.
Basin 105

NOTICE OF INTENT NO. 49481

1. OWNER DENNIS CLARK CONSTRUCTION
MAILING ADDRESS PO BOX 909
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1639 SOUTH BENTON RD.
MINDEN, NEVADA 89423

2. LOCATION NW ¼ SE ¼ Sec 26 T 13 N R 20 E DOUGLAS County

PERMIT NO. NA (Issued by Water Resources) | 1320-26-002-046 (Parcel No.) | LOT 10 AURORA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SILT CLAY		0	10	10
GRAVEL BROWN CLAY		10	100	90
SANDS & GRAVEL		100	110	10
GRAVEL BROWN CLAY		110	160	50
SANDS & GRAVEL		160	170	10
GRAVELY BROWN CLAY		170	185	15
SANDS & GRAVEL		185	200	15

Date started 03/29/, 20 04
Date completed 04/05/, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	15 TO 20	160	3.5

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	20
6"		SDR 21	20	160

Perforations:
Type perforation MILL SLOT
Size perforation 3/32"
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50' ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL

Static water level 91 feet below land surface
Artesian flow NO G.P.M P.S.I
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (CONTRACTOR)
Address PO BOX 2227 (CONTRACTOR)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed
By driller performing actual drilling on site or contractor
Date 5/10/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com