

Log No. 97048
 Permit No. _____
 Basin 032

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 34878

1. OWNER Albert W Harrison ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 936 W Winnemucca Blvd not assigned yet - RC 7-26-05
Winnemucca NV 89445
 2. LOCATION SE 1/4 NW 1/4 Sec 13 T 38 N/S R 36 E Humboldt County _____
 PERMIT NO. 005-221-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	40	
Decomposed granite/clay		40	60	
Decomposed granite		60	80	
Decomposed granite/clay		80	200	
Decomposed granite		200	220	
Decomposed granite/clay		220	240	
Decomposed granite		240	260	
Decomposed granite/clay		260	320	
Blue Clay		320	360	

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>+1</u>	<u>360</u>

Perforations:
 Type perforation punched
 Size perforation 1/4 x 1
 From 120 feet to 360 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 54 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 360 feet

Date started 5-12, 2005
 Date completed 5-20, 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>150</u>		<u>4</u>

9. WATER LEVEL
 Static water level 9.1 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling and pump Service Contractor
 Address 3040 Callahan St. Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 0020578
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208
 Signed Owen Brinkhoff
 By driller performing actual drilling on site or contractor
 Date 5-25-05