

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55738**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Stuart Feigin ADDRESS AT WELL LOCATION 125 Anitra Reno
 MAILING ADDRESS 695 Sierra Rose Dr.
Reno, NV 89511

2. LOCATION SE 1/4 NE 1/4 Sec. 02 T 18N N/S R 19E E Washoe County
 PERMIT NO. 041-290-22 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	3	3
Rusty to brown clays		3	49	46
Gray volcanic		49	70	21
Rusty brown clays		70	85	15
Rusty brown clays		85	121	36
Yellow clay		121	164	43
Brown volcanic rock		164	203	39
Brown clay		203	216	13
Gray volcanic rock		216	260	44
Yellow volcanic rock		260	267	7
Fracture	x	267	274	7
Gray volcanic rock		274	297	23
Fracture	x	297	299	2
Gray volcanic rock		299	301	2
Fracture	x	301	321	20
Gray volcanic rock		321	327	6

Washoe County Well Permit # WL 050085

8. WELL CONSTRUCTION
 Depth Drilled 327 Feet Depth Cased 327 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>100</u> Feet
<u>8 5/8</u> Inches	<u>100</u> Feet	<u>327</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>327</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3

From	To
<u>267</u> feet to	<u>327</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 327 feet

9. WATER LEVEL
 Static water level 198 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce Mackay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed R. Bruce Mackay
 By driller performing actual drilling on-site or contractor
 Date 6/9/2005

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60</u>		<u>3</u>	

RECEIVED
 05 JUN 23 AM 11:31
 STATE ENGINEERS OFFICE