

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 97080
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53116

1. OWNER CASEY PROPERTIES
 MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406
 ADDRESS AT WELL LOCATION 1910 PAM
FALLON, NV 88406

2. LOCATION NW 1/4 NW 1/4 Sec 20 T 19 N R 28 E CHURCHILL County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 008-172-19 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
BROWN SAND		1	14	13
BROWN SAND		14	18	4
BROWN SANDS/CLAY		18	40	22
GRAY SANDS		40	60	20
BLACK SILTY SAND		60	75	15
GRAY SANDS		75	85	10
GRAY CLAY		85	90	5
BROWN SANDS	X	90	105	15

8. WELL CONSTRUCTION
 Depth Drilled 105 Feet Depth Cased 105 Feet
 HOLE DIAMETER (BIT SIZE)
 From 103/4 Inches To 0 Feet 50 Feet
6 Inches 50 Feet 105 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>105</u>

RECEIVED
 05 JUN 10 AM 11:57
 STATE ENGINEERS OFFICE

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080
 From 98 feet to 102 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 18'8" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

Date started MAY 23, 20 05
 Date completed MAY 23, 20 05

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP. (CONTRACTOR)
 Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date JUNE 8, 2005

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1HR</u>