COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97082
Permit No.
Basin 101
NOTICE OF INTENT NO. 54917

1. OWNER LAHONTAN HOMES
MAILING ADDRESS 4700 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5645 ALCORN ROAD
FALLON, NV 89406

2. LOCATION NW ¼ NE ¼ Sec 32 T 19 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) 008-652-80 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	20	10
BROWN SAND		20	40	20
GRAY SANDS/CLAY		40	70	30
BROWN SANDS		70	88	18
GRAY CLAY		88	90	2
GRAY SANDS		90	140	50
GRAY CLAY		140	146	1
BROWN SANDS/GRAVEL	X	146	175	34

RECEIVED
'05 JUN 10 AM 11:57
STATE ENGINEER'S OFFICE

Date started MAY31, 20 05
Date completed MAY 31, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1 HR

8. WELL CONSTRUCTION

Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
103/4 Inches	0 Feet	100 Feet
6 Inches	100 Feet	175 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
65/8	12.9	.188	+2	175

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 169 feet to 173 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 28'3" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date JUNE 8, 2005

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. - (214) 340-9429 - FormsOnADisk.com