COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97096
Permit No.
Basin 105

NOTICE OF INTENT NO. 52302

1. OWNER DICK HANSEN
MAILING ADDRESS 1517 SANCHEZ RD
GARDNERVILLE, NV 89460

ADDRESS AT WELL LOCATION 1527 SANCHEZ RD
GARDNERVILLE, NV 89410

2. LOCATION ~~SW~~ SE ¼ ~~SW~~ NW ¼ Sec 35 T 13 N R 20 E DOUGLAS County
PERMIT NO. Issued by Water Resources | 23-295-790/1320 Parcel No. | -35-001-013 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	162	84
BROWN GUMMY CLAY		162	192	30
SMALL SILTY SANDS		192	213	21
SMSALL OBSIDIAN GRAVELS	XX	213	250	37

Date started 5/17, 20 05
Date completed 5/19, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	250 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	10
sdr21 6 5/8	4.06	.216	10	250

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 250 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAY DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 6/1/05