COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97098
Permit No.
Basin 105
NOTICE OF INTENT NO. 52310

1. OWNER JOHN PAGEN
MAILING ADDRESS GARDNERVILLE, NV 89460
ADDRESS AT WELL LOCATION 1569 BARKER GARDNERVILLE, NV 89410

2. LOCATION SW ¼ NW ¼ Sec 32 T 13 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1321-32-001-003 (Permit No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
COBBLES				
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	162	84
BROWN GUMMY CLAY		162	192	30
SMALL SILTY SANDS		192	213	21
SMSALL OBSIDIAN GRAVELS		213	240	27
COURSE FRACTURED GRAVELS		240	265	25

Date started 5/8, 20 05
Date completed 5/10, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	265 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	25
sdr21 6 5/8	4.06	.216	25	265

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 225 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 265 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAY DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 6/1/05

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429