

Log No. 97110  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53465

1. OWNER Tony Tuoto ADDRESS AT WELL LOCATION 135 FREDERICKSBURG  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 36 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. 121936-001011 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT		0	3	3
BROWN CLAY-GRAVEL		3	13	13
COBBLES	<input checked="" type="checkbox"/>	13	60	47
BROWN CLAY		60	87	27
GRANITE BOULDERS	<input checked="" type="checkbox"/>	87	108	21
DG	<input checked="" type="checkbox"/>	108	150	42

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>.188</u>	<u>1</u>	<u>10</u>
<u>6 7/8</u>	<u>4</u>	<u>SDR21</u>	<u>10</u>	<u>150</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation .045" x 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 102 ft  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 102 feet to 150 feet

9. WATER LEVEL  
 Static water level 13 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started APR 6 20 05  
 Date completed APR 7 20 05

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		<u>1.0</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
**BLAIN DRILLING & PUMP CO. INC.**  
 Name \_\_\_\_\_ P.O. Box 1255  
 Address Carson City, NV 89702  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board: 46698  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date 4-7-05