97151

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 106

NOTICE OF INTENT NO. 55774

1. OWNER Roy Funez
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1455 Hwy 395 (Holebrook Jct)

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 10 N/S R. 22 E. Douglas CO County
PERMIT NO. 10218-001-012
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil, Cobbles		1	116	
(DG) Some clay		116	33	
DG				
Granite (Some fracture)		33	146	
DG (Decomposed Granite)		146	184	
Granite fractured		184	214	
W. DG layers				
Granite		214	270	
DG layers				
(Fractured)	✓	265	water	

RECEIVED
05 JUN -2 AM 11:28
STATE ENGINEERS OFFICE

Date started 5/10/05, 20
Date completed 5/11/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75		45 mins

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		1 Feet	50 Feet
8 3/4 Inches		50 Feet	270 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	10
6 5/8	PVC	SDR 21	10	270

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 1 x 5 #5 pipe perf
From 190 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From Ø feet to Ø feet

9. WATER LEVEL
Static water level +1 feet below land surface
Artesian flow 40 G.P.M. 14 P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jason K Drilling Inc (Contractor)
Address PO 599 (Contractor)
SS NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18276
Signed (By driller performing actual drilling on site or contractor)
Date 5/12/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627