

97162
OFFICE USE ONLY

Log No. _____
 Permit No. _____
 Basin. 106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54587

1. OWNER George Walker ADDRESS AT WELL LOCATION 4200 Kyle Dr., Wellington 9th, 89447
 MAILING ADDRESS 4200 Kyle Dr., Wellington 9th, 89447
 2. LOCATION NE 1/4 NE 1/4 Sec. 14 T. 16 N/S R. 22 E Douglas County
 PERMIT NO. 1022-14001-039 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
aluminum top rock, small rock + brown clay		0	20	20
brown clay		20	52	32
brown clay + small rock		52	78	26
sharp gravel + coarse sand	yes	78	112	34
brown sandy clay		112	146	34
coarse sand + small gravel	yes	146	180	34

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10	0	50
6	50	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/4		188	0	180

Perforations:
 Type perforation Factory saw slot
 Size perforation 1/16" x 3
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started March 20, 2005
 Date completed May 21, 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	10 ft	3 hrs

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Contractor
 Address P.O. Box 92 Smith Pk. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166 A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date June 2 - 05

RECEIVED
 JUN - 3 AM 11:01
 ENGINEERS OFFICE