97180

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 105

NOTICE OF INTENT NO. 55082

1. OWNER PTP INC
MAILING ADDRESS P. O. BOX 188
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 175 HWY 395,
GARDNERVILLE, NV 89410 (HOLE # A-1)

2. LOCATION NW 1/4 NW 1/4 Sec. 5 T 11N N/S R 21E E DOUGLAS County
PERMIT NO. EPA #NV504000001 Issued by Water Resources | BIA LAND Parcel No. | PINE VIEW ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable X Rotary RVC
X Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY & ROCK		0	50	50

#8 SRI SAND WAS TREMIED FROM 50' TO 38' - #8 GRANULAR BENTONITE TREMIED FROM 38' TO 35' - PUMPED ABANDONITE FROM 35' TO 7' - POURED NEAT CEMENT FROM 7' TO SURFACE & PLACED A 22" X 22" X 3.5" CEMENT PAD AROUND A 6" X 8' STEEL LOCKING MONUMENT - WITH A 4" PVC LOCK CAP - 4" THREADED CAP WAS PLACED ON THE BOTTOM OF THE 4" PVC PIPE

Date started 4/4/2005 , 19__
Date completed 4/4/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.5	Inches	0	Feet	50	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		SCH 40	+.5	50

Perforations:
Type perforation MACHINE SLOT IN ASTM F 480 SCH 40
Size perforation .010
From 40 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 38
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: X Yes No
From 38 feet to 50 feet

9. WATER LEVEL
Static water level DRY HOLE feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
Address P.O.BOX 850 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wiese
By driller performing actual drilling on-site or contractor
Date 4/5/2005

USE ADDITIONAL SHEETS IF NECESSARY