

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

97184
 OFFICE USE ONLY

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No.
 Permit No.
 Basin 105

NOTICE OF INTENT NO. 54619

1. OWNER **PTP INC**
 MAILING ADDRESS P.O. BOX 188
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 175 HWY 395,
GARDNERVILLE, NV 89410 (HOLE B-2)

2. LOCATION NE 1/4 NE 1/4 Sec. 5 T 11N N/S R 21E E DOUGLAS County
 PERMIT NO. EPA #NV504000001 BIA LAND PINE VIEW ESTATES
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial Irrigation Test Cable
 Monitor Stock Air Rotary RVC
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY & ROCK		0	50	50
#10-20 COLORADO SILICA SAND WAS TREMIED FROM 50' TO 38' - #8 GRANULAR BENTONITE TREMIED FROM 38' TO 35' - PUMPED ABANDONITE FROM 35' TO 7' - POURED NEAT CEMENT FROM 7' TO SURFACE & PLACED A 22" X 22" X 3.5" CEMENT PAD AROUND A 6" X 8" STEEL LOCKING MONUMENT - WITH A 4" PVC LOCK CAP - 4" THREADED CAP WAS PLACED ON THE BOTTOM OF THE 4" PVC PIPE				

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
10.5 Inches From 0 Feet To 50 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>SCH 40 PVC</u>	<u>0</u>	<u>50</u>

Perforations:
 Type perforation MACHINE SLOT IN ASTM F 480 PIPE
 Size perforation .010
 From 40 feet to 50 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 38 Neat Cement
 Placement Method: Pumped Poured Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 38 feet to 50 feet

9. WATER LEVEL
 Static water level DRY HOLE feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality

Date started 4/2/2005, 19____
 Date completed 4/2/2005, 19____

7. WELL TEST DATA
 TEST METHOD: Bailor Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. BOX 850 Contractor
ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
 Signed Bradley D. Wise
 By driller performing actual drilling on-site or contractor
 Date 4/5/2005