


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



97196
 OFFICE USE ONLY

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **54602**

1. OWNER **DAN EGAN**
 MAILING ADDRESS **211 WILBUR WAY**
PAHRUMP, NV 89048-5520

ADDRESS AT WELL LOCATION **3 MILES EAST OF WELLS**
HONOR CAMP ON I-80

2. LOCATION **SE** 1/4 **SE** 1/4 Sec. **17** T **37N** N/S R **65E** E **ELKO** County
 PERMIT NO. **009-340-011** Parcel No. **PARCEL OF LAND** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	1	1
GRAVEL & WHITE ROCK		1	130	129
BROWN VOLCANIC HARD		130	240	110
BROWN VOLCANIC W/ YELLOW LIMESTONE LAYERS			440	200
BROWN SILTSTONE	XXX	440		
W/PEBBLE CONGLOMERATE			500	60

8. WELL CONSTRUCTION
 Depth Drilled **500** Feet Depth Cased **500** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
10 5/8 Inches	0 Feet	500 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1	500

Perforations:
 Type perforation **MACHINED MILL SLOT**
 Size perforation **3/16 X 3, 6 ROW**
 From **460** feet to **500** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **500** feet

9. WATER LEVEL
 Static water level **428** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.T.
 Water temperature **COLD** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** Contractor
 Address **P.O. BOX 850** Contractor
ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board **020582**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1998**
 Signed *Bradley D. Wiles*
 By driller performing actual drilling on-site or contractor
 Date **11/19/2004**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 Draw Down (Feet Below Static) Time (Hours)
12 **5 HRS**