WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97209
Permit No.
Basin 87

NOTICE OF INTENT NO. 49552

1. OWNER Airport Authority of Washoe County
MAILING ADDRESS P.O. Box 12940
Reno, NV 89502

ADDRESS AT WELL LOCATION In the area of Rewana Farms, Pamela St., Model Way and Cathy

2. LOCATION NE 1/4 NE 1/4 Sec. 30 T 19N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 25-24, 25-25, 25-26 Subdivision Name Rewana Farms

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well #29 - 6" Measured static water level at 2.0'. Measured depth of well at 85'. Installed pipe in well and blew debris form well to a depth of 91'. Installed Mills Knife and perforated 4 rows per foot from 52' to surface. We then installed 84' of tremme pipe and pumped well full of neat cement from bottom to surface. Casing was cut off 5' below surface. It was difficult to determine what well actually required for cement because we pumped from a mixer load.				

Date started 6/15/2005, 19__
Date completed 6/24/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	2'	64'

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 64'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 2.0' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 6/27/2005

USE ADDITIONAL SHEETS IF NECESSARY