WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97221
Permit No.
Basin 87

NOTICE OF INTENT NO. 49551

1. OWNER Airport Authority of Washoe County
MAILING ADDRESS P.O. Box 12940
Reno, NV 89502

ADDRESS AT WELL LOCATION In the area of Home Gardens Drive, Tyrone Way and Marvel Way in SE Reno

2. LOCATION NE 1/4 NE 1/4 Sec. 31 T 19N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 025,385,386,387-01 Subdivision Name Home Gardens

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well #58 - 6" casing				
Measured static water level at 10.1'. Depth of				
well was 9'. Installed pipe and blew debris from				
well to a depth of 52', where we hit hard bottom.				
Installed Mills Knife to 42' and perforated 4 rows				
per foot from 42' to surface. We then installed				
50' of tremme pipe, mixed 17 bags of cement with				
90 gallons of water and pumped seal in from bottom				
of well to surface. Casing was cut off 5' below				
ground level.				

Date started 5/25/2005, 19__
Date completed 6/2/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 52' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	+1	52'

Perforations:
Type perforation n/a
Size perforation n/a
From n/a feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 10.1' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 6/16/2005

USE ADDITIONAL SHEETS IF NECESSARY