WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97238
Permit No.
Basin 105

NOTICE OF INTENT NO. 51809

1. OWNER James & Gailen Bell
MAILING ADDRESS 1818 Tumbleweed Fallon NV 89406
ADDRESS AT WELL LOCATION 1905 Tedsen Gardnerville NV 89410

2. LOCATION SE ¼ NW ¼ Sec. 12 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. — (Issued by Water Resources) 1220126100 04 (Parcel No.) [redacted] (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, gravel, COBBLES, clay layers		0	105	105
[redacted] SANDY CLAY		105	180	75
gravel		180	185	5
SANDY CLAY		185	205	20
gravel	x	205	225	20
SANDY clay		225	235	10
SANDY gravel	x	235	265	30
CLAY		265	275	10
gravel	x	275	300	25

Date started 2·25· 05, 19
Date completed 3·13 05, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+-		4 hours

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 300 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	180
6 5/8		.188	200	240
			260	275
			295	300

Perforations:
Type perforation Factory Slot
Size perforation 3/32 x 3"
From feet to feet
From feet to feet
From 180 feet to 200 feet
From 240 feet to 260 feet
From 275 feet to 295 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COOL °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling & Pump (Contractor)
Address 3540 Green Acres Dr (Contractor)
Carson City NV 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John S. [signature] (By driller performing actual drilling on site or contractor)
Date 3·11·05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627