WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97240
Permit No.
Basin 106

NOTICE OF INTENT NO. 50922

1. OWNER Dale + Sharon Soule
MAILING ADDRESS PO Box 1185 Minden NV 89423
ADDRESS AT WELL LOCATION 4700 Night Hawk Gardnerville, NV 89410

2. LOCATION SW ¼ SE ¼ Sec. 08 T 09 N/S R 23 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 0923 08000012 (Parcel No.) Topaz Heights (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY / loose ROCKS		0	15	15
silty SANDY CLAY		15	205	
loose BROKEN limestone		205	285	
FRACTURED limestone		285	315	
FRACTURED limestone	600? 650?	315	700	

Date started 4·25·05, 19
Date completed 5·25·05, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	5-10		10
PUMP w/ 5 GPM pump	5	0	3

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	315 Feet
6 1/8 Inches	[illegible] Feet	[illegible] Feet
Inches	315 Feet	700 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+2	275
5"		.188	300	660

Perforations:
Type perforation Factory slot
Size perforation 3/32 x 3
From feet to feet
From 275 feet to 315 feet
From feet to feet
From 660 feet to 700 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 564 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling + Pump (Contractor)
Address 3540 Greenacre Carson City NV 89705 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-2-05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627