WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97256
Permit No.
Basin 105

NOTICE OF INTENT NO. 55770

1. OWNER D/A Development
MAILING ADDRESS NE SW
ADDRESS AT WELL LOCATION 1804 Sterling Lot 22 Ranch Rd.

2. LOCATION SE ¼ NW ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | 1220-01-002-046 Parcel No. | Sterling Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		1	2	
Cobbles, Gravel		2	21	
Clay		21	25	
Gravels, Cobbles		25	143	
Some Clay Seams		143	150	
Gravels Cobbles		150	172	
Clay Gravels		172	206	
Gravels, Cobbles		206	240	

RECEIVED
05 JUN -2 AM 11:27
STATE ENGINEERS OFFICE

Date started 5/15/05, 20
Date completed 5/17/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-25		2½ hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	50 Feet
8 3/4 Inches	50 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	PVC	SDR 21	20	240

Perforations:
Type perforation Machine Perf
Size perforation 3/16x4x4 Screen
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 87' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drillin Inc Contractor
Address PO 599 Contractor
SS NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0081841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/1/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627