

OFFICE USE ONLY
 Log No. **97261**
 Permit No. _____
 Basin **163**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28588**

1. OWNERS **Donnie + Rochelle Brown** ADDRESS AT WELL LOCATION **BASALT AV. + WINNEBAGO ST. SANDY VALLEY NV**
 MAILING ADDRESS _____
 2. LOCATION **NW 1/4 SE 1/4 Sec. 16 T. 24 N/S R. 576 E. CLARK** County
 PERMIT NO. **200-16-701-003** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY + GRAVEL		0	28	28
CALICHE		28	36	8
CLAY		36	50	14
CLAY + GRAVEL		50	122	72
CEMENTED GRAVEL ^{fractures}	W.B.	122	135	13
CLAY		135	178	43
CLAY + GRAVEL		178	255	77
GRAVEL	W.B.	255	280	25

8. WELL CONSTRUCTION
 Depth Drilled **280** Feet Depth Cased **280** Feet
 HOLE DIAMETER (BIT SIZE)
 From **10 9/8** Inches To **0** Feet **280** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	4.33	.316	0	280

Perforations:
 Type perforation **SAW CUT**
 Size perforation **1/2 INCH BY 6 INCH**
 From **280** feet to **260** feet
 From **140** feet to **120** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50 FT** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **280** feet to **50** feet

9. WATER LEVEL
 Static water level **118** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **60.2** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Budget Drilling CO** Contractor
 Address **P.O. Box 3505** Contractor
Pattonville NV. 89051
 Nevada contractor's license number issued by the State Contractor's Board **40020**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1573**
 Signed **Donnie Brown**
 By driller performing actual drilling on site or contractor
 Date **7-15-2005**

Date started **7-9**, 2005
 Date completed **7-11**, 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)