

Log No.
Permit No.
Basin. GBT

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14665

1. OWNER John Fritz ADDRESS AT WELL LOCATION 14430 Spezia
MAILING ADDRESS P. O. Box 70596 14430 Spezia
Reno, Nv 89570 Lot 123 off Mt. Rose Hwy

2. LOCATION SE 1/4 NE 1/4 Sec 30 T 18 N/S R 20 E Washoe County Washoe
PERMIT NO. 49-371-48 Government Homesites Subdivision Name Government Homesites

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Granite cobbles & boulders | | 0 | 3 | 3 |
| Tan brown white D.G. & brown clay | | 3 | 18 | 15 |
| Sands gravels with some boulders | | 18 | 79 | 61 |
| Red brown green yellow volcanic gravels with brown clay | | 79 | 187 | 108 |
| Red clay with some gravels | | 187 | 210 | 23 |
| Sticky green clay with traces of sand | | 210 | 340 | 130 |
| Red clay with some volcanic gravels | | 340 | 374 | 34 |
| Gray clay volcanic gravels | | 374 | 460 | 86 |
| T. D. 460 ft | | | | |

8. 10" - 60' WELL CONSTRUCTION
Diameter 8 1/2 inches Total depth 460 feet
Casing record 6 5/8 inch
Weight per foot 12.92 Thickness .188

| Diameter | From | To |
|---------------------|--------------------|-----------------|
| <u>6 5/8</u> inches | <u>+1 1/2</u> feet | <u>460</u> feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes No Type grout
Depth of seal 52 feet
Gravel packed: Yes No
Gravel packed from 52 feet to 460 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 440 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet

Date started 12/18/90, 19.....
Date completed 12/21/90, 19.....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|--|--------|-----------|------------------|
| <u>Blew with air to clean and develop.</u> | | | |
| | | | |
| | | | |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
Static water level 221 feet below land surface
Flow 15 G.P.M. P.S.I.
Water temperature warm °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc Contractor
Address 625 Spice Islands Dr Suite L Sparks Contractor 89431
Nevada contractor's license number 15291 issued by the State Contractor's Board
Nevada contractor's driller's number 1132 issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1911
Signed Roger M. Thrall By driller performing actual drilling on site or contractor
Date 12/28/90