

OFFICE USE ONLY
Log No. 91370
Permit No. _____
Basin 212
NOTICE OF INTENT NO. 27790

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Shenida & Louise Hagler ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3040 Rich Man SAME
Las Vegas NV 89139
2. LOCATION N 1/4 SW 1/4 Sec 20 T. 22 N/S R. 61 E Clark County
PERMIT NO. 17720302013 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay Gravel		0	30	30
Cemented Gravel		30	50	20
Brown Clay Boulders Gravel		50	200	150
layers of limestone	X	200	425	225
lime stone	X	425	500	75
Static water in old well 185				
Pumped old well with neat cement from 300 75 225				
Capped off well with 1/2 inch rock and cement 75 0 75				
Casing was perforated from 300 75 225				
logan steel casing				

DCNR/DWR RECEIVED
AUG 09 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 496 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 0 Feet 500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 IN	F480	P.I.C	1	496
5 IN	8 5/8	1 3/8	168 IN	3 1/2

Perforations:
Type perforation Saw
Size perforation 1/8 X 12

From 500 feet to 440 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 55 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No

Date started 7-27, 2005
Date completed 8-01, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>2 HRS.</u>

9. WATER LEVEL
Static water level 193 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kedding Drilling Contractor
Address 3955 Blue Diamond Rd #4 Contractor
Las Vegas, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed 8-2-05
By driller performing actual drilling on site or contractor
Date Floyd Mitchell