

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. **97498**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28229**

1. OWNER **C.R. Homes** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **1551 E. Elderberry** **1551 E. Elderberry**
Pahrump, NV 89060

2. LOCATION **NW 1/4 SE 1/4 Sec. 35 T 20** N/S R **53E** E **Nye** County
 PERMIT NO. **41-102-17** Parcel No. **Calvada Valley** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	48	48
brown caleche		48	53	5
brown loam	x	53	79	26
brown caleche	x	79	83	4
brown loam	x	83	94	11
brown caleche	x	94	102	8
See next line	x	102	104	2
brown loam with caleche strings				
brown loam	x	104	140	36
brown caleche	x	140	200	60

DCNR/DWR
 RECEIVED
 SEP 28 2005
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **200** Feet Depth Cased **200+1** Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **200** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	3.7	.280	0	200

 Perforations:
 Type perforation **sawcut**
 Size perforation **.188**
 From **160** feet to **200** feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **200** feet

9. WATER LEVEL
 Static water level **78** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **5801 S. Homestead** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**
 Signed _____ By driller performing actual drilling on-site or contractor
 Date **9.21.05**

Date started **8/12/1905** **2005** **DSB**, 19____
 Date completed **8/12/1905**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			