

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 97528
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28697

1. OWNER Steve & Barbara Harrington
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION 2360 Jayme St.

2. LOCATION SE 1/4 NW 1/4 Sec 1 T 22s N R 53 E Nye County
 PERMIT NO. 41-372-32 Calvada Valley Unit:14, Blk:22, Lot: 23

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay/Gran. Caliche		4	12	8
Brown Clay		12	35	23
Brown Clay/Caliche		35	78	43
Brown Clay/Gravel		78	85	7
Gravel		85	91	6
Brown Clay/Gravel		91	155	64
Brown Clay	X	155	172	17
Green Clay/Gravel	X	172	260	88

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.92</u>	<u>.28</u>	<u>0</u>	<u>260</u>

Perforations:
 Type perforation Saw Cut
 Size perforation 1/4" width 8" long
 From _____ 220 feet to _____ 260 feet
 From _____ feet to _____ feet

**DCNR/DWR
 RECEIVED**
 SEP 13 2005

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ 50 feet to _____ 260 feet

LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level _____ 98 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started August 8, 20 05
 Date completed September 8, 20 05

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC.
 (CONTRACTOR)

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>5</u>	<u>4</u>	<u>14</u>	

Address P.O. BOX 56
 (CONTRACTOR)
PAHRUMP, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
 Signed _____
 By driller performing actual drilling on site or contractor
 Date September 8, 2005