038501

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

2 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97630
Permit No.
Basin 212

NOTICE OF INTENT NO. 28921

1. OWNER Mike Beasley
MAILING ADDRESS 9524 W. Ramberbach Rd. Suite 130 Phoenix AZ

ADDRESS AT WELL LOCATION 3380 E. Flamingo Rd. Las Vegas Nv.

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-13-802-023 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0.0	0.3	0.3
Gravel w/Silty Sand		0.3	3.0	2.7
Caliche		3.0	4.5	1.5
Sandy Silt		4.5	14.0	9.5
Silty Sand		14.0	25.0	11.0

DCNR/DWR RECEIVED OCT 17 2005 LAS VEGAS OFFICE

Date started 10/11, 20 05
Date completed 10/12, 20 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25.0 Feet Depth Cased 25.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½ Inches		0.0 Feet	25.0 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		Sch 40 PVC	0.0	25.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 25.0 feet to 5.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25.0 feet to 3.0 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Eable Drilling Services LLC
Address (Contractor) 7150 Pecos St.
Las Vegas Nv. 89119
Nevada contractor's license number issued by the State Contractor's Board 57266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 10/12/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627