



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 28911

1. OWNER DAVID COOK ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 11005 \_\_\_\_\_  
LAS VEGAS, NV \_\_\_\_\_  
 2. LOCATION NW 1/4 SW 1/4 Sec. 27 T. 21 N/S R. 61 E CLARK County  
 PERMIT NO. R-1274 Parcel No. 162-27-301-006 Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSW

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAYY SAND		0.0	8.0	8.0
SAND W/ GRAVEL		8.0	16.0	8.0
Caliche		16.0	19.0	3.0
Clay		19.0	28.0	9.0
Silty Clay		28.0	40.0	12.0

DCNR/DWR  
 RECEIVED  
 SEP 14 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 41.0 Feet Depth Cased 40.0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 1/2 Inches To 41.0 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.0		TYPE 304	40.0	15.0
		STAINLESS STEEL		
6.0		5CU 40 PVC	15.0	0.0

Perforations:  
 Type perforation CONTINUOUS WIRE LOG  
 Size perforation 1.040  
 From 40.0 feet to 15.0 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 1  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 40.0 feet to 13.0 feet

9. WATER LEVEL  
 Static water level 31 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EPHIE DRILLING SERVICES LLC Contractor  
 Address 7150 PLACID ST Contract #  
LAS VEGAS NV 89119  
 Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272  
 Signed Munkh J...  
 By driller performing actual drilling on site or contractor  
 Date 8/23/05

Date started 8/22, 2005  
 Date completed 8/23, 2005

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)			