

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25575

1. OWNER John Mason ADDRESS AT WELL LOCATION White Wolf Canyon Triple D Ranch  
 MAILING ADDRESS \_\_\_\_\_ Dyer NV 89010

2. LOCATION SE 1/4 SW 1/4 Sec 23 T 4 N/S R 36 E Esmeralda County  
 PERMIT NO. 1001-150-03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other REPAIRED  Municipal/Industrial  Irrigation  Test  Monitor  Stock

4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG Sec other 105

Material	Water Strata	From	To	Thick-ness
<u>Abandonite product 30' x 50' x 12" lbs per gallon</u>				
<u>08" x 1 1/2" x 8' dog set (steel dog)</u>		<u>0</u>	<u>150</u>	
<u>Cement Plug Set</u>		<u>1</u>	<u>21'</u>	
<u>Cement</u>		<u>1</u>	<u>20'</u>	
<u>Well casing clean / over all intact</u>				
<u>190-200 sand removed via air purge</u>				

**DCNR/DWR RECEIVED**

NOV 14 2005

**LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
N/A Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>Approx 138</u>			

Perforations:  
 Type perforation Half Perfor  
 Size perforation 3/16 x 2 1/4 x 7# news

From 50 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal NA

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10/07/05, 20\_\_\_\_  
 Date completed 10/07/05, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Abandonment</u>		

9. WATER LEVEL  
 Static water level 109 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Mason Contractor  
 Address PO 893 Contractor  
SS NV 89408

Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 10-7-05