WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97664
Permit No.
Basin 162

NOTICE OF INTENT NO. 29129

1. OWNER GARY NALLEY
MAILING ADDRESS 1530 W AMARILLO AVE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1530 W AMARILLO AVE

2. LOCATION NE 1/4 SW 1/4 Sec. 29 T 20S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 40-251-21 (Parcel No.) CALVADA VALLEY UNIT 5 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	12	12
CALICHE		12	35	23
CLAY		35	56	21
CALICHE		56	66	10
CLAY		66	80	14
CALICHE	WB	80	84	4
CLAY		84	128	44
CALICHE	WB	128	134	6
CLAY		134	150	16
CALICHE	WB	150	165	15
CLAY		165	190	25
CALICHE	WB	190	215	25
CLAY		215	220	5

DCNR/DWR
RECEIVED
NOV 14 2005
LAS VEGAS OFFICE

Date started 11/1/2005, 19__
Date completed 11/1/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	220

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 11/4/2005

USE ADDITIONAL SHEETS IF NECESSARY