WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97676
Permit No.
Basin 117

NOTICE OF INTENT NO. 25576

1. OWNER Ralph Keyo
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lucky Co Rd

2. LOCATION SW ¼ SE ¼ Sec. 5 T. 4 N OR 36 E Comerada County
PERMIT NO. (Issued by Water Resources) 07-661-11 Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Clay		1	7	
Gravel Sand		7	26	
Sand Clay		26	67	
Gravels Sand		67	97	
Clay Sand		97	143	
Gravels Sand		143	158	
Clay		158	178	
Gravels, Clay		178	197	
Clay		197	200	

DCNR/DWR
RECEIVED
OCT 26 2005
LAS VEGAS OFFICE

Date started 10/18/05, 20
Date completed 10/19/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3½ hr

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		1 Feet	50' Feet
8 3/4 Inches		50 Feet	200' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	PVC	SDR 21	20	200

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 6 x 6 Rows perf
From 140 feet to 155 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 200' feet

9. WATER LEVEL
Static water level 86' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Contractor
Address PO 599 Contractor
[illegible] NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [illegible] By driller performing actual drilling on site or contractor
Date 10/19/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627