WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97715
Permit No. 70417
Basin 230

NOTICE OF INTENT NO. 28762

1. OWNER Tom Grose Family Trust
MAILING ADDRESS 2640 Avenue of the Stars
Pahrump, Nv. 89048

ADDRESS AT WELL LOCATION 825 S. Casada
Amargosa Valley, Nv. 89020

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 16 N/S R. 48 E. NYE County
PERMIT NO. 70417 (Issued by Water Resources) Parcel No. 19-091-18 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Compacted gravel w/sand		0	65	65
Void		65	70	5
Limestone		70	75	5
gravel w/sand	1st	75	90	15
Limestone w/sand & cly. layers		90	220	130
-Small voids thru out				
Bottom of well			220	

DCNR/DWR RECEIVED
AUG 29 2005
LAS VEGAS OFFICE

Date started 7/18, 2005
Date completed 7/22, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	220
Surface Protective Casing:				
8	Steel	.188	0	7

Perforations:
Type perforation Machined
Size perforation G.R. .032 Screen
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Cook Drilling Co.
Address (Contractor) H.C. 70 Box 543
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed (By driller performing actual drilling on site or contractor)
Date 8/20/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627