COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97776
Permit No.
Basin 069

NOTICE OF INTENT NO. 55649

1. OWNER Richard Rego
MAILING ADDRESS PO Box 184
Volcano, HI 96785

ADDRESS AT WELL LOCATION Springfield and Browning
Paradise Valley, NV 89425

2. LOCATION SE 1/4,SE 1/4 ¼ NW ¼ Sec 7 T 39 N R 39 E Humboldt County

PERMIT NO. (Issued by Water Resources) | 006-242-02 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Sand and Clay		3	25	22
Clay		25	30	5
Sand and Clay		30	40	10
Clay		40	45	5
Fine sand		45	55	10
Clay		55	60	10
Sand and clay		60	75	0
Clay		75	80	0
Sand and gravel		80	85	0
Clay		85	88	0
Sand and gravel		88	125	
				0
Clay		125	130	
Sand and gravel		130	150	0

RECEIVED 05 AUG 29 PM 1:42 STATE ENGINEER'S OFFICE

Date started August 7, 20 05
Date completed August 8, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		4

8. WELL CONSTRUCTION

Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	10	.188	+1	10
6.625	4.06	.316	10	130

Perforations:

Type perforation screen
Size perforation .050
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL

Static water level 37 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed
By driller performing actual drilling on site or contractor

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com