WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97807
Permit No.
Basin Ø61

NOTICE OF INTENT NO. 55213

1. OWNER Newmont mining Corp
MAILING ADDRESS P.O. Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION TS Ranch Dunphy, NV

2. LOCATION NE ¼ NE ¼ Sec. 11 T. 33 N/S R. 48 E. Eureka County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. TS-L3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium and Gravel				
Drill well - wash over				
Casing - pull pipe out				
Set PVC in well				
Sand and pull wash over				
at Same Time, Seal Top				
of Sand with 3/8 Hole plug				
Pour Cement Seal in top				
20' of well, Set 8" monument				
with Cap and Develope untill				
Clean				

RECEIVED
05 AUG 26 AM 11:33
STATE ENGINEERS OFFICE

Date started 7/21, 20 05
Date completed 7/21, 20 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 55 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½		¼	0	55

Perforations:
Type perforation Slot
Size perforation .020
From 35 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 20 feet

9. WATER LEVEL
Static water level 25' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed [signature] By driller performing actual drilling on site or contractor
Date 7/21/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627