WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97809
Permit No.
Basin 064

NOTICE OF INTENT NO. 55218

1. OWNER Newmont Mining Corp
MAILING ADDRESS P.O. Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION Battle mountain Trailor Park
Battle mountain, NV 89820

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 32 N/S R. 45 E. Lander County
PERMIT NO. 13603 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. BM-2 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
No well Log info Available.				
Take Static test H2O @ 30'				
Trip in well to 247' Bit Kit earth out of Bottom of Casing. Camera Log Didn't See any Perforations. So Put on Perforator and do 4-Row Perforation from 20' to 247'. Then Abandone well from Bottom to top through Drill pipe, Abandone as a 14 3/4" Hole. Hole fill up after 60 SKS of Super plug 2500 gal Slurry Pour in Cement Seal in top 20' of hole 160 SKS Cement 85 gal Slurry				

RECEIVED
AUG 26 2005
STATE ENGINEERS OFFICE

Date started 7/23, 19 05
Date completed 7/23, 19 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 247 Feet Depth Cased 247 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From Feet	To Feet
?	14 3/4	0	247

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8		3/8	0	247

Perforations:
Type perforation NONE Seen by Camera
Size perforation well open at Bottom of Casing
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 30' feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/23/05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627