WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97814
Permit No.
Basin 029

NOTICE OF INTENT NO. 56090

1. OWNER Quinn River Ranch
MAILING ADDRESS 385 Denio Hy 140
Winnemucca NV 89445

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SE ¼ Sec. 4 T. 44 N/S R. 31 E. Humbolt County
PERMIT NO. 71244 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVITE SAND		0	50	50
GRAVITE SAND W/CLAY	X	50	125	75

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
10 Inches		50 Feet	125 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	120

Perforations:
Type perforation Single Row Mill Slot
Size perforation 3/16
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 125 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANS Enterprises (Contractor)
Address 399 Denio Hy 140 (Contractor)
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0058683
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed Ralph C Schell (By driller performing actual drilling on site or contractor)
Date 9-9-05

Date started 8-15, 1905
Date completed 8-16, 1905

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEER
OCT 10 2005
RECEIVED

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627