WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97816
Permit No.
Basin 087

NOTICE OF INTENT NO. **56393**

1. OWNER Washoe County Department of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, NV 89502

ADDRESS AT WELL LOCATION 3031 Longley Lane, Reno, NV.

2. LOCATION SE 1/4 SW 1/4 Sec. 20 T 19N N/S R 20E E Washoe County
PERMIT NO. M10-1331 (Issued by Water Resources) | 21-456-18 (Parcel No.) | Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Measured static water level at a depth of 1.6'. Measured depth of well at 314.7'. Installed 305' of 2" tremme pipe. Mixed 88 bags of Portland Type II cement with approximately 450 gallons of water and pumped into well from bottom to surface. Well required 3.25 cubic yards. Actual volume of well should have required 2.25 cubic yards. (original log attached)				
Plugging for log # 93718				

RECEIVED
05 SEP 21 PM 1:18
STATE ENGINEERS OFFICE

Date started 9/12/2005, 19__
Date completed 9/13/2005, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 500' Feet Depth Cased 315' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188"	0	135'
6"		.188"	255'	275'

Perforations:
Type perforation mill slot
Size perforation 5/32"
From 135' feet to 255' feet
From 275' feet to 315' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 315'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. **WATER LEVEL**
Static water level 1.6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller R&P2265
Signed (By driller performing actual drilling on-site or contractor)
Date 9/15/2005

USE ADDITIONAL SHEETS IF NECESSARY