RECEIVED

SEP 2 0 2005

ENVIRONMENTAL PROTECTION

REPORT NO. A05.075

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 97825
PERMIT NO.
BASIN Ø83

NOTICE OF INTENT NO. 56018

1. OWNER Donald Naylor
MAILING ADDRESS 1598 Mountain Vista Way Reno, NV 89509

ADDRESS OF WELL 2549 Cartwright Rd.
Virginia City Highlands, NV 89521

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 29 T 18 R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 03-033-15 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dark green volcanic fractured rock		0	80	80
Dark green rock, less fractures		80	95	15
Red/blue volcanic rock		95	110	15
Multi color volcanic rock and		110		
gray/blue/green clay		110	140	30
Gray/blue/green clay & vol rock		140	147	7
Hard blue green volcanic rock		147	150	3
Gray-blue clay & volcanic rock		150	220	70
Multi color clay & volcanic rock		220	308	88
Blue/gray/green vol rock fractures	x	308	417	109

Notes : Latitude: N39 degrees 23.391'
Longitude: W119 degrees 38.367'

Date Started 8/23/05 Date Completed 8/25/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1 hour

8. WELL CONSTRUCTION

Depth Drilled 417 Depth Cased 417

HOLE DIAMETER (BIT SIZE)

10 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 417 Feet
Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+3	417

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 377 Feet to 417 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 417 Feet

9. WATER LEVEL
Static Water Level 131 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed [signature]
By driller performing actual drilling on site or contractor

Dated August 25, 2005