COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97870
Permit No.
Basin 101

NOTICE OF INTENT NO. 54910

1. OWNER KOPAS KONSTRUCTION
MAILING ADDRESS P. O. BOX 5024
FALLON, NV 89406

ADDRESS AT WELL LOCATION LIMA LANE, 2805
FALLON, NV 89406

2. LOCATION ~~NW~~ ¼ ~~NW~~ ¼ Sec 3 T 18 N R 28 E CHURCHILL County

PERMIT NO. 5W 5W (Issued by Water Resources) | 006-232-33 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	15	5
BROWN SAND		15	40	25
GRAY SANDS		40	80	40
BROWN SILT-CLAY		80	110	30
GRAY SAND		110	150	40
GRAY CLAY		150	160	10
GRAY SANDS		160	200	40
GRAY CLAY		200	210	10
BROWN SANDS/GRAVELS	X	210	228	18

RECEIVED 05 SEP -2 AM 10:33 STATE ENGINEER'S OFFICE

Date started JULY 22, 20 05
Date completed JULY 22, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION

Depth Drilled 228 Feet Depth Cased 228 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	228 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	228

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 222 feet to 226 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 22'." feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date AUGUST 23, 2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com