



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54206

1. OWNER MR. JOHANSON ADDRESS AT WELL LOCATION 1780 WATSON CT.,  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 26 T. 13 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 1320-26-002-041 STAR VIEW RIDGE Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	9	9
SANDY CLAY		9	16	7
SANDY CLAY w/GRAVEL		16	21	5
CLAY		21	27	6
SANDY CLAY w/GRAVEL		27	83	56
GRAVEL w/SAND		83	121	38
SANDY CLAY w/GRAVEL		121	296	175
SAND	✓	296	302	6
SANDY CLAY		302	307	5
SAND	✓	307	310	3
SANDY CLAY		310	314	4
SAND	✓	314	316	2
SANDY CLAY		316	318	2
SAND	✓	318	320	2

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased 320 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 320 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+1	20
6 5/8	4	SDR 21	20	300
6 5/8	12	.188	300	320

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 300 feet to 320 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 320 feet

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING CORPORATION  
 Contractor  
 Address 811 SPRING VALLEY DR.  
 Contractor  
GARDNERVILLE, NV 89410  
 Nevada contractor's license number issued by the State Contractor's Board 60503  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2282  
 Signed Pat J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 9/3/05

Date started 8/28, 2005  
 Date completed 9/3, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15+</u>	<u>-</u>	<u>6</u>

RECEIVED  
 05 SEP 18 AM 10  
 STATE ENGINEERS OFFICE

UTM E 0266371  
N 4315212  
NAD 83