

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54896

1. OWNER STEELHEAD INC ADDRESS AT WELL LOCATION _____
MAILING ADDRESS GARDNERVILLE, NV 3268 HIGHLAND WAY
GARDNERVILLE, NV

2. LOCATION NE 1/4 SW 1/4 Sec. 18 T. 10 N. R. 22 E DOUGLAS County
PERMIT NO. 1022-18-002-020 HOLBROOK HIGHLANDS Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/COBBLES		0	85	85
GRAVEL w/CLAY		85	141	56
CLAY		141	152	11
SANDY CLAY w/GRAVEL		152	218	66
CLAY		218	223	5
COBBLES w/SAND	✓	223	229	6
SANDY CLAY w/GRAVEL		229	242	13
SAND + GRAVEL	✓	242	246	4
SANDY CLAY w/GRAVEL		246	283	37
SAND + GRAVEL	✓	283	286	3
SANDY CLAY w/GRAVEL		286	292	6
SAND + GRAVEL	✓	292	294	2
SANDY CLAY		294	345	51
SAND	✓	345	351	6
SANDY CLAY		351	380	29

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>105/8</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>97/8</u> Inches	<u>50</u> Feet	<u>260</u> Feet
<u>57/8</u> Inches	<u>260</u> Feet	<u>380</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>12.5</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations: (STEEL) PVC
Type perforation FACTORY SLOT / SLOTTED SCREEN
Size perforation 3 x 3/32

From 240 feet to 260 feet
From 280 feet to 300 feet
From 340 feet to 360 feet } PVC

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 195 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDMUND MILLER DRILLING Contractor
Address P.O. Box 92 Contractor
SMITH, NV 89430

Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2282

Signed Paul J. Murray
By driller performing actual drilling on site or contractor
Date 8/17/05

Date started 7/22 2005
Date completed 8/12 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>10+</u>	<u>-</u>	<u>12</u>

RECEIVED
05 SEP - 8 AM 10 31
STATE ENGINEERS OFFICE