

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52260

1. OWNER LEN BOOTH ADDRESS AT WELL LOCATION Mont
MAILING ADDRESS SE NW 3551 MONTBLANC CT
2. LOCATION NE 1/4 SW 1/4 Sec 11 T. 14 S. R. 19 E Douglas County
PERMIT NO. 1419-11-001-007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG & ROCK		0	31	31
DG & BROWN CLAY		31	106	75
SOLID GRANITE		106	192	86
DG	X	192	208	16
SOLID GRANITE		208	240	32
DG	X	240	300	60

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 5/8</u>	0	75
<u>9 7/8</u>	75	125
<u>8 3/4</u>	125	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.88</u>	<u>+1</u>	<u>300</u>

Perforations:
Type perforation Factory milled
Size perforation 3/16" x 3"

From _____ feet to _____ feet
From 260 feet to 300 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 54 ft Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 54 feet to 300 feet

RECEIVED
OCT 04 2005
STATE ENGINEER'S OFFICE

9. WATER LEVEL

Static water level 175 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality CLEAR

Date started MAY 16 2005
Date completed MAY 19 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2.5+</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIR DRILLING & PUMP CO. INC.
Address PO. Box 1255 Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167

Signed Jack Watson
By driller performing actual drilling on site or contractor
Date MAY 21, 05