

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56476

1. OWNER Phillip Sheridan ADDRESS AT WELL LOCATION 492 PURSHIA HILLS RD  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW SW 1/4 SE SW 1/4 Sec 26 T. 12 N/S R. 19 E. Douglas County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 129-26002002 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	6	6
BR CLAY		6	26	20
DG AND BR CLAY		26	104	78
DG	<del>X</del>	104	129	25
FRACTURED GRANITE	<del>X</del>	129	148	19
DG	<del>X</del>	148	200	52

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 50 Feet  
9 7/8 Inches 50 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>20</u>	<u>200</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation 104.5" X 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 54 feet to 200 feet

9. WATER LEVEL  
 Static water level 72 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 88 °F Quality CLEAR

Date started 22 Sep, 2005  
 Date completed 23 Sep, 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. BOX 1255 Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date 30 Sep 05