WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97936
Permit No.
Basin 092B

NOTICE OF INTENT NO. 56394

1. OWNER Douglas Dunn
MAILING ADDRESS 11905 lemmon Drive
Reno, NV 89506

ADDRESS AT WELL LOCATION 11905 Lemon Drive, Reno, NV.

2. LOCATION NE 1/4 NE 1/4 Sec. 21 T 21N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
080-294-11 Parcel No.
Heppner Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to the well site and removed 95' of 1" drop pipe and submersible pump. Measured static water level at 84'. Measured the depth of the well at 113'. Well had a 5" liner inside of the 6" casing. Tried to remove liner but lodged in well too tightly. Installed 110' of 2" tremme pipe in well and mixed 30 bags of Portland Type II cement with approximately 150 gallons of water. Pumped in cement from bottom of well to surface. Cement did come up in the annulus between the 6" casing and 5" liner. (original log attached)				
plugging of log # 27342				

Date started 10/14/2005, 19__
Date completed 10/14/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 114 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		.156	+1	113'

Perforations:
Type perforation slotted
Size perforation 3"x3/32
From 93' feet to 113' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 113'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 84' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Tramper
By driller performing actual drilling on-site or contractor
Date 10/17/2005

USE ADDITIONAL SHEETS IF NECESSARY