WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97937
Permit No.
Basin 061

NOTICE OF INTENT NO. 55047

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 69
Carlanda NV 89414

ADDRESS AT WELL LOCATION 2 miles North of Carlanda NV

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 33 N S R. 48 E. White Pine County

PERMIT NO. 71431 (Issued by Water Resources) | Parcel No. | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Clay		3	5	2
Silt stone		5	25	20
Sand small				
gravel	40	25	50	25
Brown clay		50	70	20
Silt stone				
Some small gravel		70	300	230
Blue clay		300	360	60
Silt stone & gravel		360	400	40
Gravel & some				
Sand	400-500	400	520	120
gravel & some		520	610	90
Sand & some	500			
Clay mix				

Date started 9-22, 2005
Date completed 10-5, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
400+		48

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased 610 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
22 Inches	0 Feet	60 Feet
17½ Inches	60 Feet	610 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.250	+1½	380
10 3/4		.250	540	560
10 3/4		.250 mill.	600	610
22		.312	+1	60

Perforations:
Type perforation SS wire wrapped screen
Size perforation .85 - slot
From 380 feet to 540 feet
From 560 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 60 feet to 610' feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W NC Exploration & well (Contractor)
Address 580 W Silver ST (Contractor)
Elko NV 89801

Nevada contractor's license number issued by the State Contractor's Board 0012852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-11-05

RECEIVED 2005 OCT 24 PM 12:31 STATE ENGINEER'S OFFICE

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627