WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97967
Permit No.
Basin 045

NOTICE OF INTENT NO. 56162

1. OWNER JAN M. ROCKWELL
MAILING ADDRESS 267 SPRING CREEK PARKWAY
SPRING, CREEK, NV 89815

ADDRESS AT WELL LOCATION ~~TWO BOTTLE BAR LANE~~ -
LOT 1
761 Buck Horn Rd

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T 33N N/S R 57E E ELKO County
PERMIT NO. (Issued by Water Resources) 023-024-007 (Parcel No.) PLEASANT VALLEY (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLED SAND		0	72	72
CALICHI CLAY		72	89	17
DECOMPOSED GRANITE		89	175	86
LOOSE ALLUVIUM FAN	X	175		
WASH			190	15

Date started 10/4/2005, 19__
Date completed 10/10/2005, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	48		5

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	190	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	16
6	SDR-17		16	190

Perforations:
Type perforation SCREEN
Size perforation .050
From 50 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite 16-50
Gravel Packed: [X] Yes [ ] No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 013904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 10/28/2005

USE ADDITIONAL SHEETS IF NECESSARY