

Log No. 97974
Permit No. _____
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51403

1. OWNER John Rick ADDRESS AT WELL LOCATION 24 W 55 So. Street, Highland Drive
MAILING ADDRESS P.O. Box 150876
Ely, Nevada 89315

2. LOCATION SE 1/4 SE 1/4 Sec. 15 T. 16 N. R. 63 E White Pine County
PERMIT NO. _____ Parcel No. 3 Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Gravel		2	10	8
Course Gravel		10	14	4
Brown Clay		14	20	6
Boulders		20	25	5
Sand & Gravel with Clay Stringers		25	85	60
Clay		85	95	10
Boulders		95	100	5
Sand & Gravel		100	115	15
Sand & Gravel with Clay Stringers		115	155	40
Course Water Bearing Gravel	X	155	165	10
Sand & Gravel		165	190	25
Boulders		190	195	5
Clay		195	203	8

8. WELL CONSTRUCTION
Depth Drilled 203 Feet Depth Cased 203 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 203 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	203

Perforations:
Type perforation Factory
Size perforation 1/8" X 2 1/2" 6 Rows
From 123 feet to 203 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 203 feet

9. WATER LEVEL
Static water level 132 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started August 18 2005
Date completed September 21 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	68	1

Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Avenue Contractor
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Arnold D. Christiansen
By driller performing actual drilling on site or contractor
Date October 27, 2005

RECEIVED
2005 NOV -2 PM 3:29
STATE ENGINEERS OFFICE