WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97981
Permit No.
Basin 089

NOTICE OF INTENT NO. 55382

1. OWNER Jet Construction
MAILING ADDRESS P.O. Box 1724
Carson City, NV 89701

ADDRESS AT WELL LOCATION 153 Peppy San Court
Washoe Valley

2. LOCATION SW 1/4 SE 1/4 Sec. 5 T 16N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 050-304-17 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand		0	20	20
Sand DG gravel		20	40	20
DG gravels		40	80	40
DG little rock clay	x	80	140	60
Granite		140	180	40
Granite fracture	x	180	240	60

Washoe County Well Permit # WL 050273

Date started 10/11/2005 , 19__
Date completed 10/14/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	240

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

From		feet to	feet
From	120	feet to	140 feet
From	180	feet to	200 feet
From	220	feet to	240 feet
From		feet to	feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 10/26/2005

USE ADDITIONAL SHEETS IF NECESSARY