COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97990
Permit No.
Basin 061

NOTICE OF INTENT NO. 55512

1. OWNER Barrick Goldstrike Mines Inc. VD96-4
MAILING ADDRESS PO Box 29, Elko NV 89801
ADDRESS AT WELL LOCATION Barrick Goldstrike mine site, 30 miles North of Carlin

2. LOCATION NW ¼ NW ¼ Sec 29 T 36 N R 50 E Eureka County

PERMIT NO. ~~50855~~ (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pumped 720 gallons of				
Abantinite				
Poured 30 cubic feet				
3/8 hole plug				
Cemented 0'-20' with				
(3) bags of neat cement				

RECEIVED
OCT 04 2005
STATE ENGINEER'S OFFICE

Date started September 22, 20 05
Date completed September 22, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 810 Feet Depth Cased 810 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	20	Feet
7 3/8	Inches	20	Feet	810	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8	28	.250	0	20
7 3/8	10	.233	+2	111

Perforations:
Type perforation Mill Slot
Size perforation
From 111 feet to 810 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 102 ☒ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 102 feet to 810 feet

9. WATER LEVEL

Static water level 443 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gene Fenhaus (CONTRACTOR)
Address PO Box 5279 (CONTRACTOR)
Elko, NV
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1366

Signed
By driller performing actual drilling on site or contractor
Date September 28, 2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com